

Aerosol Storage:

Permits for the Storage of Aerosol products are required if more than 500 pounds of Level 2, Level 3 or combination of the two Aerosols are maintained on site at any point whether indoors or outdoors.

Level 2: Chemicals with heat of combustion >8,600 Btu/lb - <13,000 Btu/lb
(may include: Hairspray, Antiperspirants, Windshield De-Icer)

Level 3: Chemicals with heat of combustion >13,000 Btu/lb
(may include: Spray Paint, Lacquers, Auto Engine Cleaner, Lubricants)

Conditions of this permit are as follows:

- SDS must be available on site as well as including in the permit application process
- Inspection required
- Sprinklered system may be required
- Fire Alarm system may be required
- Fire separation may be required
- Carton must be identified at least on one side
- Level 2 aerosol maximum limits 1,000 pounds (inside)
- Level 3 aerosol maximum limits 500 pounds (inside)
- Outside storage of Level 2 and 3 shall be separated from exposures (streets, buildings, exits, etc.)

During the application process be prepared to list the quantity of each level aerosol stored as well as download the following documents: 1) A copy of your Fire Extinguisher tag(s); minimum 40 BC 2) SDS-Safety Data Sheet 3) Annual Sprinkler ITM report 4) Annual Fire Alarm ITM Report 5) Diagram of the storage area