

Dry Cleaning:

Permits for Dry Cleaning Operations are required for locations where cleaning solvents are used and stored whether inside or outside. If your facility is a drop off only with no solvents, you are not required to apply.

Classifications for Cleaning Solvents are

- Class I - with flash point < 100°F
- Class II- with flash point at or > 100°F
- Class IIIA - flash point at >140°F < 200°F
- Class IIIB - at 200°F
- Class IV - classified as nonflammable

If you are using multiple types of solvents, you will be required to list each type used or stored at your facility.

Conditions of this permit are as follows:

- SDS (Safety Data Sheets) required
- Must list classification of dry cleaner
 - Type I—systems using Class I solvent
 - Type II—systems using Class II solvent
 - Type III-A—systems using Class IIIA solvent
 - Type III-B—systems using Class IIIB solvent
- May require an inspection
- Provide fire extinguishers
- Fire alarm system required
- Required to be sprinklered (exception: Type I)

During the application process be prepared to download the following documents: 1) A copy of your Fire Extinguisher tag(s); minimum 40 BC 2) SDS/Safety Data Sheets for Chemicals 3) Annual Sprinkler ITM Report 4) Annual Fire Alarm ITM Report