

## **LPG-Propane:**

An operational permit is required for the storage and use of LP-gas

Conditions of this permit are as follows:

- Volume less than 500 gallons, cylinders cannot be located any closer than 10 feet from the means of egress from a building or tent
- Volume 501 gallons or more, cylinders cannot be located closer than 25 feet from the means of egress
- LP-gas cylinders shall be adequately protected to prevent tampering, damage by vehicles or other hazards
- Portable LP-gas containers shall be securely fastened in place to prevent unauthorized movement
- Portable fire extinguishers are required one (1) 10BC shall be available within 30 feet of the gas cylinder, one (1) Class K extinguisher shall be provided if cooking
- No Smoking signs shall be posted. No smoking is permitted within 25 feet of a LP-gas cylinder
- Standby personnel maybe required at the discretion of the fire code official

During the application process be prepared to download the following documents: 1) Photo or copy of the 40 BC fire extinguisher tag, if cooking, you must also have a Class K extinguisher, 2) Provide a site map showing the entire event area, location of set up on the property, including the location of equipment and tank(s), street intersections, land marks and buildings in close proximity.