

## **Tents & Membrane Structures:**

An operational permit is required to operate an air supported temporary membrane structure or tent have an area in excess of 400 square feet.

Conditions of this permit are as follows:

- Must provide an NFPA 701 flame spread certificate
- Certificate must match the label on the tent
- Combustibles such as hay, straw, etc. shall not be allowed (exception: food for cattle)
- No Smoking permitted
- No open or exposed flames
- Three (3) feet clearance between the tent fabric and contents
- Provide fire extinguishers
- Fireworks shall not be used within 100 feet of tent
- Tents with sidewalls or drops where cooking is performed must be 20 feet from other tents
- Use of solid flammables for warming foods such as butane or similar devices are acceptable
- LP-gas containers must be located outside tent
- Standby personnel maybe required at the discretion of the fire code official
- Crowd managers are required at the ratio of 1 per 250 people
- No permit needed for 10x10 that are not connected

During the application process be prepared to download the following documents: 1) Flame Spread Certificate, 2) Inside tent layout, 3) Site Diagram Map