

acility Inform		-	
	e: Owner's Name:		
Address:	Phone Number:		
	oning Company Information		
Company Nai	me: Technician Name:		
Address:	Phone Number:		
RP 300 Reference	Decommissioning Activity	Completed? (Y/N)	N/A
	Initiate safety procedures.		
14.6.2	Relieve pressure in the tank ullage.		
14.6.3	Drain liquid-collection points.		
14.6.4 <i>,</i> 14.6.5	Disconnect all vapor pumping or processing units.		
14.6.4	Disconnect all electrical components of the Stage II system so that no electrical hazards are created.		
14.6.4	Reprogram the dispenser electronics to reflect that Stage II vapor recovery is no longer in service.		
14.6.6	Securely seal off the below-grade vapor piping at a height below the level of the base of the dispenser.		
14.6.7	Securely seal off the below-grade vapor piping at the tank end if it is easily accessible.		
14.6.8	Securely seal the vapor piping inside the dispenser cabinet.		
14.6.9	Replace the Stage II hanging hardware with conventional hanging hardware.		
14.6.10	Install appropriate pressure/vacuum vent valve(s).		
14.6.11	Remove any Stage II instructions from the dispenser cabinet.		
14.6.12	Conduct a pressure decay test and tie-tank test.		
14.6.13	Verify that the visible components of the storage system are left in a condition that will reliably prevent the release of any vapors or liquids from any component of the system.		
14.6.13	Restore the facility to operating status.		
	NOTES		

PEI RP 300 STAGE II DECOMMISSIONING CHECKLIST SUPPLEMENTARY INFORMATION

	oning Actions							
(a) Vapor Re	covery Piping:	V		NI -	_			
	Piping Removed [if "yes", go to (b)]?:	Yes	П	No	Ц			
	Piping purged of any liquid?:	Yes						
	, Oh. O							
	Piping capped at dispenser end?:	Yes						
	Picture and at the discussion of the	V						
	Piping capped at tank end?:	Yes						
(b) Liquid Dro	op-Out Tank:							
. , .	Liquid drop-out tank present [if "no", go to (c))]?:		Yes		No □		
	Liquid drop-out tank removed [if "yes", go to	(c)]?:		Yes		No □		
	Liquid in tank evacuated?:			Yes				
	•							
	Siphon line disconnected at submersible pump and capped?:							
		Yes		Siph	on not	present 🗆		
(c) Hanging H	dardware:							
(c) Hanging i	Stage II hanging hardware replaced with non-	Stage	II eau	ipme	nt?:			
		Yes	-					
(d) Vacuum F	Pump:							
	Vacuum motor disabled or removed?	Yes						
Signatures:								
Signatures.								
					Date:			
	Technician Performing the Decommissioning							
					Date:			
	Facility Owner or Owner's Representative							