
June 29, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**MUNICIPAL AUDITORIUM
MUNICIPAL AUDITORIUM**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4524949	ENGINE ROOM	2011-06-22 @ 9:00 am	2011-06-27 @ 10:00 am	1.1	2011-06-28
4524947	JIM RAVER'S	2011-06-22 @ 9:00 am	2011-06-27 @ 10:00 am	< 0.3	2011-06-28
4524948	MACHINE SHOP	2011-06-22 @ 9:00 am	2011-06-27 @ 10:00 am	0.8	2011-06-28
4524946	TICKET - BACK OF	2011-06-22 @ 9:00 am	2011-06-27 @ 10:00 am	< 0.3	2011-06-28
4524945	TICKET OFFICE	2011-06-22 @ 9:00 am	2011-06-27 @ 10:00 am	< 0.3	2011-06-28
4524944	TICKET OFFICE	2011-06-22 @ 9:00 am	2011-06-27 @ 10:00 am	< 0.3	2011-06-28

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498