
September 7, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
CONSERVANCY

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4526427	BERGER	2011-08-31 @ 10:00 am	2011-09-06 @ 10:00 am	1.3	2011-09-07
4526426	RAPOPORT	2011-08-31 @ 10:00 am	2011-09-06 @ 10:00 am	1.0	2011-09-07
4526425	RAPOPORT	2011-08-31 @ 10:00 am	2011-09-06 @ 10:00 am	1.1	2011-09-07

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

September 7, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
ELIZABETH PARK

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4526429	GAME ROOM	2011-08-31 @ 11:00 am	2011-09-06 @ 10:00 am	2.2	2011-09-07
4526428	MAIN OFFICE	2011-08-31 @ 11:00 am	2011-09-06 @ 10:00 am	2.2	2011-09-07
4526430	MULTIPURPOSE ROO	2011-08-31 @ 11:00 am	2011-09-06 @ 10:00 am	2.4	2011-09-07

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

September 7, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
HADLEY PARK

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4526433	COFFEE ROOM	2011-08-31 @ 12:00 pm	2011-09-06 @ 10:00 am	< 0.3	2011-09-07
4526435	FITNESS ROOM	2011-08-31 @ 12:00 pm	2011-09-06 @ 10:00 am	< 0.3	2011-09-07
4526434	FITNESS ROOM	2011-08-31 @ 12:00 pm	2011-09-06 @ 10:00 am	< 0.3	2011-09-07
4526431	MANUEL	2011-08-31 @ 11:00 am	2011-09-06 @ 10:00 am	< 0.3	2011-09-07
4526432	RUCKER	2011-08-31 @ 11:00 am	2011-09-06 @ 10:00 am	0.6	2011-09-07

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

September 7, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
MAINTENANCE

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4526417	CUSTODIAL	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	< 0.3	2011-09-07
4526416	FISHER	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	< 0.3	2011-09-07
4526411	HENRY	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	1.7	2011-09-07
4526410	LANTZ	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	1.7	2011-09-07
4526412	MORGAN	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	0.9	2011-09-07
4526414	WATKINS	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	0.8	2011-09-07
4526413	WATKINS	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	0.7	2011-09-07
4526415	WRIGHT	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	0.9	2011-09-07

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

September 7, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
MASONRY

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4526449	BREAK ROOM	2011-09-01 @ 10:00 am	2011-09-06 @ 10:00 am	6.6	2011-09-07
4526448	BREAK ROOM	2011-09-01 @ 10:00 am	2011-09-06 @ 10:00 am	6.9	2011-09-07

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

September 7, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
PARKS ADMIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4526406	BROWN	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	3.6	2011-09-07
4526404	CORLEW	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	3.4	2011-09-07
4526408	DAVIS	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	4.3	2011-09-07
4526409	DEVAULT	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	4.3	2011-09-07
4526405	KOSTERN	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	3.2	2011-09-07
4526407	LUCKETT	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	4.2	2011-09-07
4526403	RICHARD	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	3.2	2011-09-07
4526402	RICHARD	2011-08-31 @ 9:00 am	2011-09-06 @ 9:00 am	3.5	2011-09-07

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

September 7, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
REC OFFICE

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4526421	BROWN	2011-08-31 @ 10:00 am	2011-09-06 @ 10:00 am	0.8	2011-09-07
4526419	FLOYD	2011-08-31 @ 10:00 am	2011-09-06 @ 10:00 am	0.8	2011-09-07
4526422	KELLEY	2011-08-31 @ 10:00 am	2011-09-06 @ 10:00 am	0.7	2011-09-07
4526418	PARRISH	2011-08-31 @ 10:00 am	2011-09-06 @ 10:00 am	0.8	2011-09-07
4526423	TROUP	2011-08-31 @ 10:00 am	2011-09-06 @ 10:00 am	0.9	2011-09-07
4526420	WALKER	2011-08-31 @ 10:00 am	2011-09-06 @ 10:00 am	0.8	2011-09-07

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

September 7, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
SPORTSPLEX

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4526440	AQUATIC	2011-09-01 @ 10:00 am	2011-09-06 @ 11:00 am	0.8	2011-09-07
4526438	DENISE	2011-09-01 @ 9:00 am	2011-09-06 @ 11:00 am	0.7	2011-09-07
4526446	FITNESS ROOM	2011-09-01 @ 10:00 am	2011-09-06 @ 11:00 am	0.5	2011-09-07
4526445	FITNESS ROOM	2011-09-01 @ 10:00 am	2011-09-06 @ 11:00 am	0.8	2011-09-07
4526443	FRANK	2011-09-01 @ 10:00 am	2011-09-06 @ 11:00 am	< 0.3	2011-09-07
4526439	JAMIE	2011-09-01 @ 9:00 am	2011-09-06 @ 11:00 am	1.0	2011-09-07
4526437	JOHN	2011-09-01 @ 9:00 am	2011-09-06 @ 11:00 am	0.8	2011-09-07
4526436	JOHN	2011-09-01 @ 9:00 am	2011-09-06 @ 11:00 am	0.7	2011-09-07
4526442	KENT	2011-09-01 @ 10:00 am	2011-09-06 @ 11:00 am	< 0.3	2011-09-07
4526444	MANUEL	2011-09-01 @ 10:00 am	2011-09-06 @ 11:00 am	< 0.3	2011-09-07
4526441	RICK	2011-09-01 @ 10:00 am	2011-09-06 @ 11:00 am	0.7	2011-09-07

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498