
October 4, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

PAR- MASONRY BUILDING

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4527272	BREAK ROOM	2011-09-29 @ 9:00 am	2011-10-03 @ 8:00 am	4.1	2011-10-04
4527271	BREAK ROOM	2011-09-29 @ 9:00 am	2011-10-03 @ 8:00 am	4.1	2011-10-04

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 4, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

PAR-CLEVELAND PK COMM CTR

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4527195	ARTS &CRAFTS RO	2011-09-28 @ 11:00 am	2011-10-03 @ 9:00 am	3.8	2011-10-04
4527194	ARTS &CRAFTS RO	2011-09-28 @ 11:00 am	2011-10-03 @ 9:00 am	3.7	2011-10-04
4527196	CLUB ROOM	2011-09-28 @ 11:00 am	2011-10-03 @ 9:00 am	3.6	2011-10-04
4527193	GAME ROOM	2011-09-28 @ 11:00 am	2011-10-03 @ 9:00 am	5.5	2011-10-04
4527192	MAIN OFFICE	2011-09-28 @ 11:00 am	2011-10-03 @ 9:00 am	4.2	2011-10-04

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 4, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

PAR-MCCABE CLUBHOUSE

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4527200	CLUB ROOM	2011-09-28 @ 12:00 pm	2011-10-03 @ 9:00 am	5.5	2011-10-04
4527270	STAFF OFFICE	2011-09-28 @ 12:00 pm	2011-10-03 @ 9:00 am	4.4	2011-10-04

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 4, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

PAR-MCCABE COMM CENTER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4527197	MAIN OFFICE	2011-09-28 @ 11:00 am	2011-10-03 @ 9:00 am	0.8	2011-10-04

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 4, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

PAR-MCCABE GOLF MAINTENANCE

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4527199	OFFICE	2011-09-28 @ 12:00 pm	2011-10-03 @ 9:00 am	1.9	2011-10-04

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 4, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
PARK PARTHENON

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4527183	BACK OFFICE	2011-09-28 @ 10:00 am	2011-10-03 @ 10:00 am	3.5	2011-10-04
4527182	BACK OFFICE	2011-09-28 @ 10:00 am	2011-10-03 @ 10:00 am	3.5	2011-10-04
4527184	FRONT OFFICE	2011-09-28 @ 10:00 am	2011-10-03 @ 10:00 am	2.9	2011-10-04
4526900	GIFT SHOP	2011-09-28 @ 10:00 am	2011-10-03 @ 10:00 am	1.5	2011-10-04
4527185	LARRILL	2011-09-28 @ 10:00 am	2011-10-03 @ 10:00 am	2.9	2011-10-04
4527186	WESLEY	2011-09-28 @ 10:00 am	2011-10-03 @ 10:00 am	2.4	2011-10-04

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 4, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
PARK POLICE

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4526893	WOOD SHOP	2011-09-28 @ 9:00 am	2011-10-03 @ 10:00 am	1.2	2011-10-04
4526895	WOOD SHOP OFFICE	2011-09-28 @ 9:00 am	2011-10-03 @ 10:00 am	1.1	2011-10-04
4526894	WOOD SHOP OFFICE	2011-09-28 @ 9:00 am	2011-10-03 @ 10:00 am	0.9	2011-10-04

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 4, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
PARK- CAAC

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4526899	BLUE ROOM	2011-09-28 @ 9:00 am	2011-10-03 @ 10:00 am	2.0	2011-10-04
4526898	DANCE OFFICE	2011-09-28 @ 9:00 am	2011-10-03 @ 10:00 am	1.8	2011-10-04
4526897	DANCE STUDIO	2011-09-28 @ 9:00 am	2011-10-03 @ 10:00 am	< 0.3	2011-10-04
4526896	VISUAL ART	2011-09-28 @ 9:00 am	2011-10-03 @ 10:00 am	2.8	2011-10-04

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 4, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
PARK-CAC

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4527189	CLASSROOM 1	2011-09-28 @ 10:00 am	2011-10-03 @ 10:00 am	6.6	2011-10-04
4527191	CLASSROOM 2	2011-09-28 @ 10:00 am	2011-10-03 @ 10:00 am	5.3	2011-10-04
4527187	DIRECTOR	2011-09-28 @ 10:00 am	2011-10-03 @ 10:00 am	6.7	2011-10-04
4527188	STAFF OFFICE	2011-09-28 @ 10:00 am	2011-10-03 @ 10:00 am	4.8	2011-10-04

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

October 4, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
PARKS ADMIN

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4526892	DAVIS	2011-09-28 @ 9:00 am	2011-10-03 @ 8:00 am	5.3	2011-10-04
4526891	DEVAULT	2011-09-28 @ 9:00 am	2011-10-03 @ 8:00 am	5.4	2011-10-04
4526890	LUCKETT	2011-09-28 @ 9:00 am	2011-10-03 @ 8:00 am	4.9	2011-10-04

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498