

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**ANTIOCH COMM CENTER**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527490	GAME ROOM	2011-10-07 @ 10:00 am	2011-10-10 @ 7:00 am	2.0	2011-10-11
4527491	HOME WORK ROOM	2011-10-07 @ 10:00 am	2011-10-10 @ 7:00 am	2.1	2011-10-11
4527492	MAIN OFFICE	2011-10-07 @ 10:00 am	2011-10-10 @ 7:00 am	1.9	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**BEAMAN NATURE CENTER**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527276	MAIN OFFICE	2011-10-05 @ 9:00 am	2011-10-10 @ 9:00 am	< 0.3	2011-10-11
4527275	STAFF OFFICE	2011-10-05 @ 9:00 am	2011-10-10 @ 9:00 am	< 0.3	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**BELLEVUE COMM CENTER**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527286	CLUB ROOM 1	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	6.6	2011-10-11
4527285	CLUB ROOM 2	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	6.3	2011-10-11
4527279	GAME ROOM	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	4.0	2011-10-11
4527280	MAIN OFFICE	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	6.7	2011-10-11
4527283	POTTER ROOM 1	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	5.5	2011-10-11
4527282	POTTER ROOM 1	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	5.2	2011-10-11
4527284	POTTER ROOM 2	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	5.9	2011-10-11
4527281	REC ROOM	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	17.5	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**BELLS BEND NATURE CENTER**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527278	DIRECTORS OFFICE	2011-10-05 @ 10:00 am	2011-10-10 @ 9:00 am	7.7	2011-10-11
4527277	STAFF OFFICE	2011-10-05 @ 10:00 am	2011-10-10 @ 9:00 am	7.2	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**CANE RIDGE CENTER**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527488	ENTRY ROOM	2011-10-07 @ 9:00 am	2011-10-10 @ 7:00 am	1.3	2011-10-11
4527489	MAIN MEETING ROO	2011-10-07 @ 9:00 am	2011-10-10 @ 7:00 am	1.3	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**HARPETH HILLS GOLF CLUB HOUSE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527293	DIRECTORS OFFICE	2011-10-05 @ 12:00 pm	2011-10-10 @ 10:00 am	0.8	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**HARPETH HILLS GOLF MAINTENANCE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527295	OFFICE	2011-10-05 @ 12:00 pm	2011-10-10 @ 10:00 am	2.0	2011-10-11
4527294	OFFICE	2011-10-05 @ 12:00 pm	2011-10-10 @ 10:00 am	2.0	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**MUSEUM OF NATURAL HISTORY**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527289	SANDRA	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	6.1	2011-10-11
4527290	STAFF OFFICE	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	7.2	2011-10-11
4527288	VERA	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	6.7	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498



---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PAR-HAMILTON CK MARINA**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527493	MAIN OFFICE	2011-10-07 @ 10:00 am	2011-10-10 @ 9:00 am	< 0.3	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**PAR-STONE HALL**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527496	DINNING ROOM	2011-10-07 @ 11:00 am	2011-10-10 @ 10:00 am	4.9	2011-10-11
4527495	LIVING ROOM	2011-10-07 @ 11:00 am	2011-10-10 @ 10:00 am	5.3	2011-10-11
4527494	LIVING ROOM	2011-10-07 @ 11:00 am	2011-10-10 @ 10:00 am	5.0	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PAR-TWO RIVERS GOLF CLUB HOUSE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527588	OFFICE	2011-10-07 @ 12:00 pm	2011-10-10 @ 11:00 am	4.6	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PAR-TWO RIVERS GOLF MAINTENANCE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527587	BREAK ROOM	2011-10-07 @ 12:00 pm	2011-10-10 @ 10:00 am	0.9	2011-10-11
4527586	MERIT	2011-10-07 @ 12:00 pm	2011-10-10 @ 10:00 am	0.8	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PAR-TWO RIVERS GROUNDS MAINTENANCE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527500	BREAK ROOM	2011-10-07 @ 12:00 pm	2011-10-10 @ 10:00 am	0.8	2011-10-11
4527499	RAINES	2011-10-07 @ 12:00 pm	2011-10-10 @ 10:00 am	0.8	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**PAR-TWO RIVERS MANSION**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527497	LIVING ROOM	2011-10-07 @ 11:00 am	2011-10-10 @ 10:00 am	3.2	2011-10-11
4527498	MEETING ROOM	2011-10-07 @ 11:00 am	2011-10-10 @ 10:00 am	3.5	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**WARNE FOWP HEAD QUARTERS**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527487	KING	2011-10-06 @ 3:00 pm	2011-10-10 @ 11:00 am	7.0	2011-10-11
4527484	MAGGIE	2011-10-06 @ 3:00 pm	2011-10-10 @ 11:00 am	6.4	2011-10-11
4527486	PARRISH	2011-10-06 @ 3:00 pm	2011-10-10 @ 11:00 am	6.1	2011-10-11
4527485	WILLIS	2011-10-06 @ 3:00 pm	2011-10-10 @ 11:00 am	7.5	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**WARNER GOLF CLUB HOUSE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527297	OFFICE	2011-10-05 @ 1:00 pm	2011-10-10 @ 11:00 am	2.8	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498



---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**WARNER GOLF MAINTENANCE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527298	OFFICE	2011-10-05 @ 1:00 pm	2011-10-10 @ 11:00 am	1.4	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**WARNER OFFICE 2**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527291	STAFF OFFICE	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	6.6	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**WARNER PARK MAINTENANCE**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527299	POWELL	2011-10-05 @ 1:00 pm	2011-10-10 @ 11:00 am	1.0	2011-10-11
4527300	STAFF OFFICE	2011-10-05 @ 1:00 pm	2011-10-10 @ 11:00 am	0.9	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:

**WARNER PARK NATURE CENTER**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527287	OFFICE	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	1.3	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**WARNER PARK OFFICE 2**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527292	DEBRA	2011-10-05 @ 11:00 am	2011-10-10 @ 10:00 am	6.1	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 11, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**WAVE COUNTRY**

---

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
4527589	DIRECTORS OFFICE	2011-10-07 @ 1:00 pm	2011-10-10 @ 11:00 am	1.5	2011-10-11
4527590	STAFF OFFICE	2011-10-07 @ 1:00 pm	2011-10-10 @ 11:00 am	1.9	2011-10-11

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498