

---

October 20, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**CEDAR HILL PARK**

---

| <b>Kit #</b> | <b>Room Id</b>   | <b>Started</b>        | <b>Ended</b>          | <b>pCi/L</b> | <b>Analyzed</b> |
|--------------|------------------|-----------------------|-----------------------|--------------|-----------------|
| 4527598      | DIRECTORS OFFICE | 2011-10-12 @ 10:00 am | 2011-10-17 @ 10:00 am | 0.8          | 2011-10-19      |

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 20, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**HERMITAGE COMM CENTER**

---

| <b>Kit #</b> | <b>Room Id</b> | <b>Started</b>        | <b>Ended</b>         | <b>pCi/L</b> | <b>Analyzed</b> |
|--------------|----------------|-----------------------|----------------------|--------------|-----------------|
| 4527600      | GAME ROOM 1    | 2011-10-12 @ 10:00 am | 2011-10-17 @ 9:00 am | 8.3          | 2011-10-19      |
| 4527683      | GAME ROOM 2    | 2011-10-12 @ 10:00 am | 2011-10-17 @ 9:00 am | 8.5          | 2011-10-19      |
| 4527682      | GAME ROOM 2    | 2011-10-12 @ 10:00 am | 2011-10-17 @ 9:00 am | 8.5          | 2011-10-19      |
| 4527599      | MAIN OFFICE    | 2011-10-12 @ 10:00 am | 2011-10-17 @ 9:00 am | 8.7          | 2011-10-19      |

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

---

October 20, 2011

**\*\* LABORATORY ANALYSIS REPORT \*\***

---

Radon test result report for:  
**MADISON COMM CENTER**

---

| <b>Kit #</b> | <b>Room Id</b>   | <b>Started</b>        | <b>Ended</b>          | <b>pCi/L</b> | <b>Analyzed</b> |
|--------------|------------------|-----------------------|-----------------------|--------------|-----------------|
| 4527596      | CLUB ROOM 1      | 2011-10-12 @ 9:00 am  | 2011-10-17 @ 10:00 am | 1.7          | 2011-10-19      |
| 4527595      | CLUB ROOM 2      | 2011-10-12 @ 9:00 am  | 2011-10-17 @ 10:00 am | 1.4          | 2011-10-19      |
| 4527594      | CLUB ROOM 2      | 2011-10-12 @ 9:00 am  | 2011-10-17 @ 10:00 am | 1.5          | 2011-10-19      |
| 4527591      | DIRECTORS OFFICE | 2011-10-12 @ 9:00 am  | 2011-10-17 @ 10:00 am | 1.7          | 2011-10-19      |
| 4527592      | GAME ROOM        | 2011-10-12 @ 9:00 am  | 2011-10-17 @ 10:00 am | 1.5          | 2011-10-19      |
| 4527593      | PROBATION OFFICE | 2011-10-12 @ 9:00 am  | 2011-10-17 @ 10:00 am | 1.5          | 2011-10-19      |
| 4527597      | STAFF OFFICE     | 2011-10-12 @ 10:00 am | 2011-10-17 @ 10:00 am | 1.1          | 2011-10-19      |

---

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498