

Radon test result report for:
BRIDGESTONE ARENA

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4527690	ADMIN - CENTER	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	< 0.3	2011-11-22
4527691	ADMIN - LEFT	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	< 0.3	2011-11-22
4527689	ADMIN - RIGHT	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	< 0.3	2011-11-22
4442496	BOX OFFICE OFFIC	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	0.6	2011-11-22
4442495	BOX OFFICE WINDO	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	< 0.3	2011-11-22
4527686	COMMISSARY	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	< 0.3	2011-11-22
4442499	CSC	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	0.6	2011-11-22
4442498	DNCHR OFFICE	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	0.6	2011-11-22
4442497	EVENT SERVICES	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	< 0.3	2011-11-22
4442500	GUEST PATH	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	< 0.3	2011-11-22
4527684	OPERATIONS	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	< 0.3	2011-11-22
4527687	SECURITY	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	0.5	2011-11-22
4527688	SMS	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	< 0.3	2011-11-22
4527685	SPORT SERVICES	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	< 0.3	2011-11-22
4442494	TSHF	2011-11-16 @ 10:00 am	2011-11-21 @ 10:00 am	0.6	2011-11-22