
November 22, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

SHERIFF – ADC

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442344	ADMIN. ASST. OFF	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	16.7	2011-11-22
4442343	ADMIN. ASST. OFF	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	16.2	2011-11-22
4442345	ADMINISTRATION	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	12.3	2011-11-22
4442346	PROGRAM DIRECTOR	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	14.4	2011-11-22
4442347	SU. OPERATIONS	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	9.9	2011-11-22

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

November 22, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

SHERIFF – ADMINISTRATION

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442350	FINANCE	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	< 0.3	2011-11-22
4442348	H.R. OPEN AREA	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	< 0.3	2011-11-22
4442349	J. PORTER OFFICE	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	< 0.3	2011-11-22

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

November 22, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
SHERIFF – CDC

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442358	ANN GREEN	2011-11-16 @ 11:00 am	2011-11-21 @ 9:00 am	1.7	2011-11-22
4442361	AUSTIN BODIE	2011-11-16 @ 11:00 am	2011-11-21 @ 9:00 am	1.5	2011-11-22
4442362	CLASSIFICATION	2011-11-16 @ 11:00 am	2011-11-21 @ 9:00 am	1.0	2011-11-22
4442360	JOYCE HEWD	2011-11-16 @ 11:00 am	2011-11-21 @ 9:00 am	1.6	2011-11-22
4442363	MEDICAL OFFICE #	2011-11-16 @ 11:00 am	2011-11-21 @ 9:00 am	3.6	2011-11-22
4442359	SHRETTI	2011-11-16 @ 11:00 am	2011-11-21 @ 9:00 am	1.6	2011-11-22

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

November 22, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

SHERIFF – CDF

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442364	LT. OFFICE	2011-11-16 @ 11:00 am	2011-11-21 @ 9:00 am	0.9	2011-11-22
4442366	MARSHA TRAVIS	2011-11-16 @ 11:00 am	2011-11-21 @ 9:00 am	0.9	2011-11-22
4442365	MEDICAL	2011-11-16 @ 11:00 am	2011-11-21 @ 9:00 am	1.0	2011-11-22
4442367	PSY. OFFICE	2011-11-16 @ 11:00 am	2011-11-21 @ 9:00 am	1.1	2011-11-22

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

Radon test result report for:
SHERIFF – CJC

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442333	BOOKING OFFICE	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	1.0	2011-11-22
4442332	BOOKING OFFICE	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	0.9	2011-11-22
4442338	BOOKING SCREENIN	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	0.6	2011-11-22
4442340	BOOKING SUPERVIS	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	0.8	2011-11-22
4442336	ICE OFFICE (1)	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	0.9	2011-11-22
4442337	ICE OFFICE (2)	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	0.8	2011-11-22
4442342	MASTER CONTROL	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	0.7	2011-11-22
4442341	MEDICAL INTAKE	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	1.0	2011-11-22
4442334	OFFICER OPEN BOO	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	0.8	2011-11-22
4442339	OFFICER STATION	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	0.8	2011-11-22
4442335	SGT. OFFICE	2011-11-15 @ 1:00 pm	2011-11-21 @ 9:00 am	0.7	2011-11-22

November 22, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
SHERIFF – TRAINING ACADEMY

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442357	DISPATCH	2011-11-15 @ 2:00 pm	2011-11-21 @ 9:00 am	9.3	2011-11-22
4442351	KRISTI OFFICE	2011-11-15 @ 2:00 pm	2011-11-21 @ 9:00 am	0.8	2011-11-22
4442356	OP OFFICE	2011-11-15 @ 2:00 pm	2011-11-21 @ 9:00 am	8.4	2011-11-22
4442355	OP OFFICE	2011-11-15 @ 2:00 pm	2011-11-21 @ 9:00 am	8.5	2011-11-22
4442354	OP OFFICE	2011-11-15 @ 2:00 pm	2011-11-21 @ 9:00 am	8.5	2011-11-22

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

November 22, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
SHERIFF – WARRANTS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4442352	DIANE'S DESK	2011-11-15 @ 2:00 pm	2011-11-21 @ 9:00 am	12.2	2011-11-22
4442353	OUTSIDE J.T. OFF	2011-11-15 @ 2:00 pm	2011-11-21 @ 9:00 am	14.4	2011-11-22

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498