
December 13, 2011

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
FAIRGROUNDS

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
4540798	BLANK	2011-12-08 @ 11:00 am	2011-12-12 @ 10:00 am	< 0.3	2011-12-13
4540797	MAINTENANCE OFFI	2011-12-08 @ 11:00 am	2011-12-12 @ 10:00 am	9.3	2011-12-13
4540796	MAINTENANCE OFFI	2011-12-08 @ 11:00 am	2011-12-12 @ 10:00 am	5.9	2011-12-13
4540795	MAINTENANCE OFFI	2011-12-08 @ 11:00 am	2011-12-12 @ 10:00 am	7.9	2011-12-13

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498