

Community Centers Radon Test Results 2018-2019

<u>Community Center</u>	<u>Page #</u>
1. Antioch Community Center	<u>2</u>
2. Cleveland Community Center	<u>3</u>
3. Coleman Park Community Center	<u>4</u>
4. Easley Center at Rose Park	<u>5</u>
5. East Community Center	<u>6</u>
6. Elizabeth Senior Center	<u>7</u>
7. Morgan Community Center	<u>7</u>
8. Hadley Community Center	<u>8</u>
9. Hartman Community Center	<u>9</u>
10. Hermitage Community Center	<u>10</u>
11. McFerrin Community Center	<u>11</u>
12. McCabe Community Center	<u>12</u>
13. Kirkpatrick Community Center	<u>12</u>
14. Looby Community Center	<u>13</u>
15. Napier Community Center	<u>14</u>
16. Old Hickory Community Center	<u>15</u>
17. Parkwood Community Center	<u>16</u>
18. Sevier Community Center	<u>17</u>
19. Smith Springs Community Center	<u>18</u>
20. Shelby Community Center	<u>19</u>
21. South Inglewood Community Center	<u>20</u>
22. Watkins Community Center	<u>21</u>
23. West Community Center	<u>22</u>
24. Madison Community Center	<u>23</u>

July 17, 2019

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

ANTIOCH COMMUNITY CENTER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9203120	STAFF DESK	2019-06-18 @ 11:00 am	2019-06-20 @ 11:00 am	1.4 ± 0.4	2019-06-24

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9059698	2018-10-02	12:00 pm	2018-10-04	12:00 pm	73	CLEVELAND CENTER		TECHNOLOGY LAB		3	3.0
9059699	2018-10-02	12:00 pm	2018-10-04	12:00 pm	73	CLEVELAND CENTER		TEEN ROOM		3	2.9
9059700	2018-10-02	12:00 pm	2018-10-04	12:00 pm	72	CLEVELAND CENTER		FRONT OFFICE		3	3.3

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9088388	2018-11-13	11:00 am	2018-11-15	11:00 am	70	COLEMAN CENTER		MULTI PURPOSE ROOM		3	1.2
9088389	2018-11-13	11:00 am	2018-11-15	11:00 am	69	COLEMAN CENTER		DANCE ROOM		3	1.7
9088390	2018-11-13	11:00 am	2018-11-15	11:00 am	66	COLEMAN CENTER		ART ROOM		3	2.0
9088391	2018-11-13	11:00 am	2018-11-15	11:00 am	68	COLEMAN CENTER		STAFF OFFICE		3	2.7

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9059355	2018-09-24	12:00 pm	2018-09-26	12:00 pm	77	EASLEY CENTER AT ROSE PARK		CLUB ROOM 2		3	< 0.3
9059356	2018-09-24	12:00 pm	2018-09-26	12:00 pm	78	EASLEY CENTER AT ROSE PARK		COMPUTER ROOM		3	< 0.3
9059357	2018-09-24	12:00 pm	2018-09-26	12:00 pm	78	EASLEY CENTER AT ROSE PARK		OFFICE		3	< 0.3

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9059362	2018-09-25	10:00 am	2018-09-27	12:00 pm	74	EAST REGIONAL CENTER		STAFF ROOM		3	< 0.3
9059363	2018-09-25	10:00 am	2018-09-27	12:00 pm	75	EAST REGIONAL CENTER		ARTS & AMP; CRAFTS ROOM		3	0.5
9059364	2018-09-25	10:00 am	2018-09-27	12:00 pm	77	EAST REGIONAL CENTER		SENIOR LIVING ROOM		3	< 0.3

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9088282	2018-10-30	12:00 pm	2018-11-01	1:00 pm	70	MORGAN COMMUNITY CENTER		CLUB ROOM		3	< 0.3
9088283	2018-10-30	12:00 pm	2018-11-01	1:00 pm	66	MORGAN COMMUNITY CENTER		OFFICE		3	2.4
9088284	2018-10-30	12:00 pm	2018-11-01	1:00 pm	73	ELIZABETH COMMUNITY CENTER		LOUNGE/T.U. ROOM		3	1.6
9088285	2018-10-30	12:00 pm	2018-11-01	1:00 pm	78	ELIZABETH COMMUNITY CENTER		ACTIVITY ROOM		3	2.1

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

July 17, 2019

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

HADLEY COMMUNITY CENTER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9203112	CENTER OFFICE	2019-06-17 @ 11:00 am	2019-06-19 @ 11:00 am	< 0.3	2019-06-21
9203111	DANCE ROOM	2019-06-17 @ 11:00 am	2019-06-19 @ 11:00 am	< 0.3	2019-06-21

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9203106	2019-06-25	10:00 am	2019-06-27	12:00 pm	70	HARTMAN COMMUNITY CENTER		FRONT OFFICE		3	< 0.3
9203107	2019-06-25	10:00 am	2019-06-27	12:00 pm	71	HARTMAN COMMUNITY CENTER		CLASSROOM ON RIGHT		3	< 0.3

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

July 17, 2019

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

HERMITAGE COMMUNITY CENTER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9203114	CLASSROOM 1	2019-06-17 @ 12:00 pm	2019-06-19 @ 12:00 pm	2.1 ± 0.3	2019-06-21
9203115	STAFF OFFICE AREA	2019-06-17 @ 12:00 pm	2019-06-19 @ 12:00 pm	1.8 ± 0.3	2019-06-21

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9059695	2018-10-02	11:00 am	2018-10-04	11:00 am	74	MCFERRIN CENTER		MULTI PURPOSE ROOM		3	< 0.3
9059696	2018-10-02	11:00 am	2018-10-04	11:00 am	75	MCFERRIN CENTER		FRONT OFFICE		3	0.9
9059697	2018-10-02	11:00 am	2018-10-04	11:00 am	75	MCFERRIN CENTER		ARTS & AMP; CRAFTS		3	0.6

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9059365	2018-09-25	11:00 am	2018-09-27	12:00 pm	72	KIRKPATRICK COMMUNITY CENTER		SMALL CLUB ROOM		3	2.5
9059366	2018-09-25	11:00 am	2018-09-27	12:00 pm	72	KIRKPATRICK COMMUNITY CENTER		HOMEWORK ROOM		3	2.0
										3	
										3	

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9059268	2018-09-10	12:00 pm	2018-09-12	1:00 pm	73	LOOBY COMMUNITY CENTER		OFFICE		3	1.3
9059269	2018-09-10	12:00 pm	2018-09-12	1:00 pm	74	LOOBY COMMUNITY CENTER		CLASSROOM		3	0.9

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9088392	2018-11-13	12:00 pm	2018-11-15	12:00 pm	69	NAPIER CENTER		FRONT CLUB ROOM		3	2.1
9088393	2018-11-13	12:00 pm	2018-11-15	12:00 pm	63	NAPIER CENTER		CLUB ROOM/ON THE LEFT		3	4.4
9088394	2018-11-13	12:00 pm	2018-11-15	12:00 pm	73	NAPIER CENTER		OFFICE		3	2.2

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

July 17, 2019

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

OLD HICKORY COMMUNITY CENTER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9203116	CLASSROOM 1	2019-06-17 @ 1:00 pm	2019-06-19 @ 1:00 pm	2.4 ± 0.3	2019-06-21
9203117	STAFF OFFICE AREA	2019-06-17 @ 1:00 pm	2019-06-19 @ 1:00 pm	2.2 ± 0.3	2019-06-21

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9054847	2018-10-02	12:00 pm	2018-10-04	12:00 pm	64	PARKWOOD CENTER		MULTI PURPOSE ROOM		3	0.7
9054871	2018-10-02	12:00 pm	2018-10-04	12:00 pm	74	PARKWOOD CENTER		STAFF ROOM		3	1.1
9059333	2018-10-02	12:00 pm	2018-10-04	12:00 pm	70	PARKWOOD CENTER		9999		3	< 0.3

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9059358	2018-09-24	1:00 pm	2018-09-27	12:00 pm	70	SEVIER		STAFF ROOM		3	1.6
9059359	2018-09-24	1:00 pm	2018-09-27	12:00 pm	73	SEVIER		CLUB ROOM		3	0.5
9059360	2018-09-24	1:00 pm	2018-09-27	12:00 pm	74	SEVIER		MANGER&APOS;S OFFICE		3	2.0
9059361	2018-09-24	1:00 pm	2018-09-27	12:00 pm	70	SEVIER		9999		3	< 0.3

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

July 17, 2019

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:
SMITH SPRINGS CENTER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9203118	DANCE ROOM	2019-06-18 @ 10:00 am	2019-06-20 @ 10:00 am	< 0.3	2019-06-24
9203119	STAFF AREA	2019-06-18 @ 10:00 am	2019-06-20 @ 10:00 am	< 0.3	2019-06-24

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9059367	2018-09-25	12:00 pm	2018-09-28	11:00 am	75	SHELBY CENTER		GAME ROOM		3	4.3
9059368	2018-09-25	12:00 pm	2018-09-28	11:00 am	78	SHELBY CENTER		CLUB ROOM 1		3	7.9
9059369	2018-09-25	12:00 pm	2018-09-28	11:00 am	76	SHELBY CENTER		READING ROOM		3	4.2
9059370	2018-09-25	12:00 pm	2018-09-28	11:00 am	75	SHELBY CENTER		OFFICE		3	6.6

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

July 17, 2019

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

INGLEWOOD COMMUNITY CENTER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9203121	FAR LEFT ROOM	2019-06-18 @ 11:00 am	2019-06-20 @ 11:00 am	2.0 ± 0.4	2019-06-24
9203122	STAFF OFFICE	2019-06-18 @ 11:00 am	2019-06-20 @ 11:00 am	1.1 ± 0.4	2019-06-24

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9059353	2018-09-24	11:00 am	2018-09-27	11:00 am	77	WATKINS		CLASSROOM ON THE LEFT		3	1.5
9059354	2018-09-24	11:00 am	2018-09-27	11:00 am	77	WATKINS		OFFICE		3	1.8

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9088395	2018-11-13	1:00 pm	2018-11-15	1:00 pm	58	WEST CENTER		PLAY ROOM		3	
9088396	2018-11-13	1:00 pm	2018-11-15	1:00 pm	71	WEST CENTER		POTTERY ROOM		3	14.0
9088397	2018-11-13	1:00 pm	2018-11-15	1:00 pm	77	WEST CENTER		CLUB ROOM/CLASSROOM		3	
9088398	2018-11-13	1:00 pm	2018-11-15	1:00 pm	75	WEST CENTER		OFFICE		3	10.2

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

I2356 / ROAA YOUSIF

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9203247	2019-08-23	10:00 am	2019-08-27	10:00 am	74	MADISON COMMUNITY CENTER		STAFF OFFICE		3	< 0.3

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498