



NOTE:  
 36" MINIMUM FOR EXISTING SIDEWALK MAINTENANCE  
 60" NEW SIDEWALK CONSTRUCTION

GENERAL NOTES:

1. SEE STANDARD DRAWINGS ST-209 AND ST-210 FOR EXPANSION JOINT LAYOUT, TRANSVERSE JOINT MARKINGS LAYOUT, FURNISHING ZONE, LAYOUT VARIATIONS FOR SIDEWALKS AND FURNISHING ZONE, AND GENERAL NOTES FOR SIDEWALK CONSTRUCTION.
2. ONE-HALF INCH EXPANSION JOINT MATERIAL TO BE USED.
3. COMPACTED STONE BASE, PUG MILL MIX, 4" THICK SHALL BE APPLIED TO SUBGRADE PRIOR TO INSTALLING SIDEWALK.
4. CROSS-SLOPE OF SIDEWALK SHALL NOT EXCEED 1:48 (VERTICAL:HORIZONTAL).
5. OBSTRUCTIONS NOT ALLOWED IN NEW RIGHTS-OF-WAY.
6. IN THE EVENT OF ANY CONFLICT, DISCREPANCY, OR INCONSISTENCY AMONG THE PLANS AND THESE STANDARD DETAILS, THE REQUIREMENTS OF THE STANDARD DETAILS SHALL GOVERN.

NOT TO SCALE

METROPOLITAN GOVERNMENT OF NASHVILLE AND DAVIDSON COUNTY DEPARTMENT OF PUBLIC WORKS	<b>OBSTRUCTION          IN          SIDEWALK</b>	DWG. NO. ST-211
DIR. OF ENG.:	<i>Mark Macy</i> DATE: 7/15/04	REVISED: 11/24/03 REVISED: 02/17/04 REVISED: 06/23/04